

## NOTES:

- 1. ENCLOSURE SHALL BE NEMA 4 RATED, 16" DEPTH.
- 2. ENCLOSURE SHALL BE CONSTRUCTED OF 14 GA COLD ROLLED STEEL.
- 3. ENCLOSURE SHALL BE PAINTED ASA 61 GREY. TWO COATS OF BAKED ENAMEL APPLIED OVER A ZINC RICH PRIMER.
- 4. NAMEPLATE #1 SHALL BE 3" X 5" AND SHALL DEPICT THE TANK NUMBER AS ISSUED BY THE DOW.
- 5. ENCLOSURE SHALL BE SUPPLIED BY HOFFMAN ENGINEERING CO.
- 6. NAMEPLATE #6 SHALL BE 3" X 5" AND DEPICT THE TANK LEVEL IN FEET.
- 7. \*REFER TO L-8701N FOR #11 ITEM IDENTIFICATION.

REV. 2004

CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF WATER

APPROVED
ADMINISTRATOR

CITY OF COLUMBUS, OHIO
STANDARD DETAIL
TANK MULTIPLEXER PANEL
ENCLOSURE